

TALEX(converter LCU 15 W 12 V outdoor IP67

LCU outdoor IP67

Product description

- · Constant voltage LED control gear
- Universal input voltage range
- Constant output voltage
- Connection: Cable with end sleeves (length approx. 500 mm)
- Polarity identifiers, secondary + red / black
- Metal casing, encapsulated
- Nominal life-time up to 50,000 h (at ta 40 °C with a failure rate max. 0.2 % per 1,000 h)
- 5-year guarantee
- Complies with CLASS C from minimum to maximum load range according to EN 61000-3-2

Properties

- · High efficiency
- Low power loss
- Overtemperature protection
- Overload protection by restricting output
- Short-circuit shutdown feature with automatic restart
- SELV
- Type of protection IP67
- Metal casing

119,6 107,6 128,6

| Ordering data |
|---------------|
|---------------|

| Туре | Article number | Packaging, carton | Packaging, pallet | Weight per pc. |
|-----------------|----------------|-------------------|-------------------|----------------|
| LCU 015/12 D010 | 24166316 | 20 pc(s). | 800 pc(s). | 0.4 kg |

Technical data

| Rated supply voltage | 120 – 240 V |
|--|------------------|
| Input voltage, AC | 108 – 264 V |
| Rated current (at 230 V 50 Hz) | 0.21 A |
| Mains frequency | 50 / 60 Hz |
| Efficiency | > 75 % |
| λ (at 230 V 50 Hz) | 0.4 |
| Output voltage tolerance | + 10 % |
| Output power | 15 W |
| Output power range | 1 – 15 W |
| Turn on time (output) | ≤ 0.5 s |
| Turn off time (output) | ≤ 1 S |
| Hold on time at power failure (Output) | 10 ms |
| Ambient temperature ta | -25 +50 °C |
| Ambient temperature ta (at life-time 50,000 h) | -25 +40 °C |
| Storage temperature ts | -30 +85 °C |
| Dimensions LxWxH | 129 x 52 x 32 mm |
| Hole spacing D | 120 mm |

Specific technical data

| Туре | Max. casing temperature to | Output voltage | Max. input power | Output current range | Max. output voltage® |
|-----------------|----------------------------|----------------|------------------|----------------------|----------------------|
| LCU 015/12 D010 | 70 °C | 12 V | 18 W | 0.08 - 1.25 A | 13.2 V |

[®] At failure mode (230 V, 50 Hz).

Standards

EN 55015

EN 61000-3-2

EN 61000-3-3

EN 61347-1

EN 61347-2-13

EN 61547

EN 62384

Overload protection

Automatic shutdown of the LED control gear if the maximum output current is exceeded. Automatic restart if the output current is below the limit.

No-load operation

The LED control gear is not damaged in the no-load operation. The max. output voltage (see page1) can be obtained during no-load operation.

Over temperature protection

Automatic power reduction of the LED control gear if the temperature limit is exceeded. Automatic restart to nominal mode if the temperature falls below the limit.


Maximum loading of automatic circuit breakers

| Automatic circuit breaker type | C10 | C13 | C16 | C20 | B10 | B13 | B16 | B20 | Inrush | n current |
|--------------------------------|---------------------|--------------------|---------------------|---------------------|---------------------|---------------------|---------------------|--------------------|------------------|-----------|
| Installation Ø | 1.5 mm ² | $1.5\mathrm{mm}^2$ | 1.5 mm ² | 2.5 mm ² | 1.5 mm ² | 1.5 mm ² | 1.5 mm ² | $2.5\mathrm{mm}^2$ | I _{max} | time |
| LCU 015/0012 D010 | 12 | 18 | 24 | 28 | 6 | 9 | 12 | 14 | 84 A | 0.06 ms |

Harmonic distortion in the mains supply (at 230 V/50 Hz and full load) in %

| Туре | THD | 3 | 5 | 7 | 9 | 11 |
|-------------------|-----|----|----|----|----|----|
| LCU 015/0012 D010 | 88 | 42 | 39 | 35 | 29 | 24 |

Wiring diagram



Installation instructions

The switching of LEDs on secondary side is not permitted.

A proper functioning of the LCU in combination with third party

A proper functioning of the LCU in combination with third party dimming devices (e.g. PWM) cannot be guaranteed.

Isolation and electric strength testing of luminaires

Electronic devices can be damaged by high voltage. This has to be considered during the routine testing of the luminaires in production.


According to IEC 60598-1 Annex Q (informative only!) or ENEC 303-Annex A, each luminaire should be submitted to an isolation test with $500\,V_{DC}$ for 1 second. This test voltage should be connected between the interconnected phase and neutral terminals and the earth terminal.

The isolation resistance must be at least $2 M\Omega$.

As an alternative, IEC 60598-1 Annex Q describes a test of the electrical strength with $1500\,V_{AC}$ (or $1.414\,x\,1500\,V_{DC}$). To avoid damage to the electronic devices this test must not be conducted.

Connection

| Prin | nary | Secondary | | |
|------------|------|-----------|-------|--|
| cal | ble | cable | | |
| L | N | + | _ | |
| brown blue | | red | black | |



PRI:

 \emptyset 7.7 ±0.2 mm; 2 x 1.04 mm² (17 AWG)

SEC

Ø 8 ±0.2 mm; 2 x 1.31 mm² (16 AWG)

Additional information

Additional technical information at $\underline{www.tridonic.com} \rightarrow Technical Data$

Guarantee conditions at www.tridonic.com → Services

No warranty if device was opened.